

1

2

3

4

REVISIONS

REV.	DESCRIPTION	DATE	DRAWN	APPROVED
A	FIRST ISSUE	15/02/17	BAF	---

NOTES.

SUITABILITY - THIS SITE PREPARATION IS APPLICABLE FOR AQUAMATE 3-RING (2210mm) AND 4-RING (2895mm) TANKS ONLY.

WARRANTY - AQUAMATE WARRANTY IS SUBJECT TO SITE PREPARATION AS PER THESE INSTRUCTIONS


NOTIFICATION - ONCE THE SITE PREP IS COMPLETE, CONTACT AQUAMATE AND YOU WILL BE PROVIDED WITH AN INSTALLATION DATE

INSTRUCTIONS


1. THE TANK PAD DIAMETER MUST BE AT LEAST 2m LARGER THAN THE TANK FOR INSTALLATION
2. REMOVE ALL LOAM, VEGETATION AND SHARP OBJECTS FROM TANK PAD LOCATION
3. WHEN EXCAVATING A SITE, ADEQUATE DRAINAGE MUST BE INSTALLED TO ALLOW WATER TO BE DIVERTED AROUND THE TANK
4. WHEN USING FILL TO LEVEL A SITE, ADEQUATE RETAINING MUST BE INSTALLED TO MAINTAIN PAD INTEGRITY
5. TANK PAD MATERIAL MUST BE CRUSHED STONE OR SIMILAR, WITH PARTICLE SIZE 6mm OR LESS. TANK PAD BASE TO BE 75mm THICK AND LEVEL WITHIN $\pm 10\text{mm}$
6. ONCE COMPLETE, ENSURE ANY DAMAGE BY VEHICLES OR LIVESTOCK IS ADEQUATELY REPAIRED
7. PROVIDE CLEAN WASHED BEDDING SAND IN A PILE NEAR THE CENTRE OF THE TANK PAD NO EARLIER THAN THREE DAYS PRIOR TO INSTALLATION
8. TANK INSTALLER TO SPREAD SAND ON SITE AS PART OF THE TANK INSTALLATION
9. ON THE DAY OF INSTALLATION, THE CUSTOMER IS REQUIRED TO HAVE AVAILABLE:
 - A) ENOUGH WATER TO FILL 10% OF THE TANK VOLUME WHILE THE INSTALLER IS ON SITE
 - B) SOMEONE TO ADVISE WHERE NOZZLES ARE TO BE INSTALLED
 - C) PAYMENT OF ANY BALANCE DUE PRIOR TO INSTALLATION
10. ONCE THE TANK INSTALLATION IS COMPLETE, PLACE A LAYER OF FREE DRAINING AGGREGATE AROUND THE PERIMETER OF THE TANK TO REDUCE BASE EROSION



TANK PAD PLAN



SECTION A



TANK WALL DETAIL

REFERENCE QUANTITIES

TANK MODEL	G052	G076	G103	G134	G170	G210	G254	G302	G355	G411	G472	G537	G607
DIAMETER	3.7m	4.5m	5.2m	5.9m	6.7m	7.4m	8.2m	8.9m	9.7m	10.4m	11.2m	11.9m	12.6m
PAD DIAMETER	5.7m	6.5m	7.2m	7.9m	8.7m	9.4m	10.2m	10.9m	11.7m	12.4m	13.2m	13.9m	14.6m
SAND QTY	0.3m ³	0.5m ³	0.6m ³	0.8m ³	1.1m ³	1.3m ³	1.6m ³	1.9m ³	2.2m ³	2.5m ³	2.9m ³	3.3m ³	3.8m ³

AQUAMATE
 16 DRURY TERRACE
 CLOVELLY PARK SA 5042
 P. +61 (0)8 8277 5777
 aquamate.com.au
 info@aquamate.com.au

INIT.	DATE	DESCRIPTION
DRAWN BY	BAF	15/02/17
CHECKED		
APPROVED		
ISSUED		

SCALE N.T.S

SHEET 1 of 1

DWG No. Z-00-1000-00002

SHEET SIZE A4 ISO

1

2

3

4